

Water Meter Sizing Form

One Form Per Meter

Preparer's Information:	Project Information:		Date ====>						
Name =======>	Permit or AR Number								
Title ======>	Name of Project ===>								
Company=====>	Project Address ===>								
Address =====>									
Phone ======>									
Email Address ====>									
Please Note:									
 All commercial facilities must be metered separately from residential facilities with and designed for the exclusive use of the residents within such development. 	the exception of those comm	ercial facilities that are within a r	master metered	residential development					
2. The Design Engineer/Architect must submit signed and sealed documentation suppand the table on page 3, unless approved otherwise by Utility Deviation. If an increase appropriate box below. A Utility Deviation will not be required for increasing meter size factors before selecting the final meter size. 3. For remodeling projects this form must be submitted only if there is a net increase.	e in meter size is requested to e for fire flow requirements. F	accommodate for fire flow, the	Engineer/Archi	tect should check					
This Section to be filled	d out by Engineer/Archi	itect of Record:							
Demand in accordance with the Fixture Flow Value Worksheet and the Table for Estimating Demand	Meter Size Required:		_						
GPM	Meter Size Requested:		_						
		_							
If the meter size requested is larger than the meter size required per the table below, please indicate the reason for the request by checking the appropriate box:									
☐ Fire Flow ☐ Other (Please attach Utility Deviation	on approval)		1						
		Demand Range (GPM)	Meter Size						
		0 to 30	3/4"						
		30.1 to 50	1"						
Type or Print Name of Engineer/Architect of Record for Project		50.1 to 100	1 1/2"						
		100.1 to 160	2"						
		160.1 to 435	3"						
		435.1 to 750	4"						
Signature of Engineer/Architect of Record for Project and Date		750.1 to 1600	6"						
[Affix Engineering/Architect Seal Here]		1600.1 to 2800	8"						
		2800.1 to 4200	10"						

Demand ranges from AWWA M22 Table 6-1 Third Edition



Fixture Flow Value Worksheet

Please call Public Utilities Engineering (239) 252-2380 with any questions.

Fixture	Occupancy	Type of Supply Control	Load Values, in Water Supply Fixture Units (wsfu) Total		# of Fixtures Per Unit	Fixture Flow Value
Bathroom group	Private	Flush tank	3.6	X		=
Bathroom group	Private	Flushometer valve	8	X		=
Bathtub	Private	Faucet	1.4	х		=
Bathtub	Public	Faucet	4	x		=
Bidet	Private	Faucet	2	x		=
Combination fixture	Private	Faucet	3	x		=
Dishwashing machine	Private	Automatic	1.4	x		=
Drinking fountain	Offices, etc.	3/8" valve	0.25	x		=
Kitchen sink	Private	Faucet	1.4	x		=
Kitchen sink	Hotel, restaurant	Faucet	4	x		=
Laundry trays (1 to 3)	Private	Faucet	1.4	x		=
Lavatory	Private	Faucet	0.7	х		=
Lavatory	Public	Faucet	2	x		=
Service sink	Offices, etc.	Faucet	3	x		=
Shower head	Public	Mixing valve	4	x		=
Shower head	Private	Mixing valve	1.4	х		=
Urinal	Public	1" flushometervalve	10	x		=
Urinal	Public	3/4" flushometervalve	5	x		=
Urinal	Public	Flush tank	3	X		=
Washing machine (8 lb)	Private	Automatic	1.4	X		=
Washing machine (8 lb)	Public	Automatic	3	X		=
Washing machine (15 lb)	Public	Automatic	4	X		=
Water closet	Private	Flushometer valve	6	x		=
Water closet	Private	Flush tank	2.2	x		=
Water closet	Public	Flushometer valve	10	х		=
Water closet	Public	Flush tank	5			=
Water closet	Public or private	Flushometer tank	2	X		=
For any fixtures not listed, s	submit manufacturer's c	lata sheets and enter appro	opriate description ar	nd value:		
Other:				x		=
Other:				x		=
Other:				x		=
Other:				x		=
Other:				х		=
				Number	Total Fixture Value Per of Units with this Fixture Co	

Number of Units with this Fixture Count =====>

Grand Total of Fixture Flow Value (Per Unit Total x Number of Units)** =====>

Fixture Flow Value worksheet from FBC 2023 edition

^{**}Use total Fixture Flow Value on "Table for Estimating Demand" to estimate water meter demand.



Table for Estimating Demand

Please call Public Utilities Engineering (239) 252-2380 with any questions.

Load	ad Value to get Fixture Flow Demand	VALVES Load Demand		
Fixture Flow Value	Gallons per minute	Fixture Flow Value	Gallons per minute	
1	3.0			
2	5.0			
3	6.5			
4	8.0			
5	9.4	5	15.0	
6	10.7	6	17.4	
7	10.7	7	19.8	
			22.2	
<u>8</u> 9	12.8	<u>8</u> 9	24.6	
	13.7		27.0	
10	14.6	10		
11	15.4	11	27.8	
12	16.0	12	28.6	
13	16.5	13	29.4	
14	17.0	14	30.2	
15	17.5	15	31.0	
16	18.0	16	31.8	
17	18.4	17	32.6	
18	18.8	18	33.4	
19	19.2	19	34.2	
20	19.6	20	35.0	
25	21.5	25	38.0	
30	23.3	30	42.0	
35	24.9	35	44.0	
40	26.3	40	46.0	
45	27.7	45	48.0	
50	29.1	50	50.0	
60	32.0	60	54.0	
70	35.0	70	58.0	
80	38.0	80	61.2	
90	41.0	90	64.3	
100	43.5	100	67.5	
120	48.0	120	73.0	
140	52.5	140	77.0	
160	57.0	160	81.0	
180	61.0	180	85.5	
200	65.0	200	90.0	
225	70.0	225	95.5	
250	75.0	250	101.0	
275	80.0	275	104.5	
300	85.0	300	108.0	
400	105.0	400	127.0	
500	124.0	500	143.0	
750	170.0	750	177.0	
1,000	208.0	1,000	208.0	
1,250	239.0	1,250	239.0	
1,500	269.0	1,500	269.0	
1,750	297.0	1,750	297.0	
2,000	325.0	2,000 325		
2,500	380.0	2,500 380.0		
3,000	433.0	3,000	433.0	
4,000	535.0	4,000	535.0	

Table for estimating demand taken from Florida Building Code 2023 Edition