

PIPE SIZE IN INCHES	RESTRAINED PIPE LENGTH IN FEET							
	VERTICAL BENDS							
	90°		45°		22-1/2°		11-1/4°	
	UPPER	LOWER	UPPER	LOWER	UPPER	LOWER	UPPER	LOWER
4	60	24	25	10	12	5	6	3
6	85	34	35	14	17	7	9	3
8	110	43	45	18	22	9	11	9
10	133	52	55	21	27	10	13	5
12	155	60	64	25	31	12	15	6
16	198	76	82	31	40	15	20	8
18	218	83	90	35	44	17	22	8
20	238	90	98	37	47	18	23	9
24	277	104	115	43	55	21	27	10
30	330	122	136	51	66	24	33	12
36	379	139	156	57	75	28	38	14

PIPE SIZE IN INCHES	RESTRAINED PIPE LENGTH IN FEET (1)	
	TEE (3)	REDUCER (4)
6 x 4	0	40
6 x 6	34	
8 x 4	0	72
8 x 8	55	
10 x 6	3	74
10 x 10	75	
12 x 4	0	122
12 x 8	31	75
12 x 12	95	
16 x 6	0	153
16 x 10	44	107
16 x 16	134	
18 x 8	0	157
18 x 12	68	108
18 x 18	152	
20 x 10	20	161
20 x 16	120	77
20 x 20	170	
24 x 12	37	187
24 x 18	132	109
24 x 24	204	
30 x 16	78	213
30 x 20	138	165
30 x 30	252	
36 x 18	84	259
36 x 24	170	191
36 x 36	298	

PIPE SIZE IN INCHES	RESTRAINED PIPE LENGTH IN FEET				
	HORIZONTAL BENDS				DEAD ENDS (2)
	90°	45°	22-1/2°	11-1/4°	
4	23	9	5	2	55
6	32	13	6	3	77
8	40	17	8	4	100
10	48	20	10	5	120
12	56	23	11	6	141
16	71	29	14	7	181
18	77	32	15	8	200
20	84	35	17	8	218
24	96	40	19	10	253
30	112	47	22	11	303
36	127	53	25	13	350

NOTES:

1. RESTRAIN ALL PIPE JOINTS WITHIN THE DISTANCE SHOWN ON THE TABLES MEASURED FROM THE POINT OF CONNECTION.
2. ISOLATION VALVES SHALL BE TREATED AS DEAD ENDS. WITH RESTRAINT ON BOTH SIDES OF THE VALVE.
3. RESTRAINT IS FOR BRANCH OF TEE. IF BRANCH SIZE IS NOT ON TABLE, USE NEXT LARGEST BRANCH.
4. RESTRAINT IS FOR LARGE DIAMETER SIDE OF REDUCER. IF REDUCER SIZE IS NOT ON TABLE, USE NEXT SMALLER REDUCER (SMALL END).
5. THIS SCHEDULE IS TO BE USED FOR DUCTILE IRON AND PVC PIPE.

PIPE RESTRAINT SCHEDULE

NTS

REVISION DATE:
JANUARY 2025



SHEET NO.

G-10